

# Certificate of Conformity

02.01.2025

UPCOM Telekomunikasyon Bilisim Teknolojileri Sanayi Ve Ticaret Limited Sirketi

Address: Kucuksu Mah. Rasathane Cad. No: 35R2 D:2 PO:34684 Uskudar Istanbul Türkiye

Certificate Number: 25-01

Issued to: UPCOM Telekomunikasyon Bilisim Teknolojileri Sanayi Ve Ticaret Limited Sirketi

Address: Kucuksu Mah. Rasathane Cad. No: 35R2 D:2 PO:34684 Uskudar Istanbul Türkiye

We, UPCOM Telekomunikasyon Bilisim Teknolojileri Sanayi Ve Ticaret Limited Sirketi, hereby certify that the fiber optic cables described below comply with the requirements of EN 50200 - Methods of test for resistance to fire of unprotected small cables for use in emergency circuits.

## Product Information:

Product Code: U-DQ(ZN)MT(SR)H (FR-FE180 PH120) -24 FO

Description: Fiber optic cable designed for use in emergency circuits with enhanced fire resistance performance.

Class of Performance: B2ca -s1a, d1, a1

Color: Orange (RAL2008)

Batch/Lot Number: 2405264-0001

## Test Compliance:

The product has been tested in accordance with EN 50200 standards and has demonstrated compliance with the following parameters:

Resistance to fire performance as specified in EN 50200.

Adherence to the Class of Performance: B2ca -s1a, d1, a1.

Durability and reliability under fire exposure conditions.

## Supporting Documentation:

- 1- Fire Resistance Test Report
- 2- Test Prosedure

## Declaration:

This Certificate of Conformity is issued based on thorough testing and quality assurance processes. We confirm that the above-mentioned product meets the specified standards and requirements as per EN 50200.

Authorized Signature:

Quality Control Manager 02.01.2025